

DATE: December 17, 2021
DISTRICT NAME: Lapeer Community Schools
SUBJECT: Addendum to Security Camera (RFP)

Questions and Answers

Note: **Add Bid Alternate: Server at Each Building Location has been added to this RFP request.

Timeline: Product availability issues

The current timeline is the ideal timeline. Please put in an exception to document any issues such as product availability, wait times, pricing issues, etc.

Realtime access is necessary for the Police department

Due to RFP materials not being accessible on the SIGMA website when posted, the District will accept proposals from vendors who were not able to attend the walkthrough meeting. An intent to bid form will still be required. A secondary walkthrough date will not be scheduled.

Q: Server location

A: Centralized at Lapeer Schools ACS or Oakland Schools ISD Waterford, TBD

Q: Is POE Provided by the district?

A: All switches provide POE to the devices.

Q: Camera MP Standard?

A: 5MP for External Cameras and Internal Large viewing areas, i.e. gym/cafeteria/hallways
2MP for Internal Small Viewing areas i.e. stairwell/vestibule

Q: Wiring standard cat 6 or 6e?

A: Cat 6 is acceptable - Must be plenum rated

Cabling will go to the closest idf/mdf to each camera

Patch Panels are required - supplied by vendor

Any lifts that are needed must be provided by the vendor

Most buildings have drop ceilings, there is one building (CFI) with Metal Ceilings

Q: Are there spare metal ceiling tiles?

A: Yes

Q: Is there a preferred manufacturer for the cameras or system?

A: No

Q: For external parking lot cameras - do the light poles have constant power?

Lapeer Community Schools (131046)

A: Every pole has power, may have inconsistent configuration across the district

Q: Cable Color: Black or Blue

A: Green for security, or a color not Blue or Red, based on availability

MDF/IDF closets have either a 2 post or rack setup.

Q: Demo and removal of the old system is required?:

A: Yes as per the RFP

Q: Mount on the ceiling or the walls: This will vary depending on location and need for the locations.

A: Pathways to the cameras are the vendors responsibility.

Q: Are boxes and conduit allowed for any surface mount cameras?

A: No. Preferred out of sight. If unavoidable, work with the district to identify the best solution.

Q: Warranty - 3 yr, 5yr Page 12 of RFP?

A: System end to end: 5 Year

Correction of Faulty Work: 3 Year

Camera Number Corrections

Center for Innovation (CFI)	33 Internal	9 External	42 Total
Lynch Elementary	13 Internal	5 External	18 Total
Lapeer High School	35 Internal	14 External	49 Total
ASC	5 Internal	6 External	11 Total